


Hearth Products Controls Co CSA CERTIFIED FIRE PIT INSERT OUTDOOR USE ONLY FOR COMMERCIAL AND RESIDENTIAL USE




MATERIAL:
FIRE BOWL INSERT - 304 STAINLESS STEEL
BOWL - COPPER


PART NUMBER	WATER SCUPPER	IGNITION	STND BTU	VOLTAGE
SIER36-EI	NO	ELECTRONIC	50K	120VAC/24VAC
SIER36W-EI	YES	ELECTRONIC	50K	120VAC/24VAC
SIER36-MLFPK	NO	MATCH LIT	50K	-
SIER36W-MLFPK	YES	MATCH LIT	50K	-

HEARTH PRODUCTS CONTROLS 3050 PLAINFIELD RD.

KETTERING, OH 45432 TOLL FREE: 1-877-433-7001 PHONE: (937) 433-7000

FAX: (937) 433-0704 www.hpcfire.com





MATCH LIT OPTION

Notes:

- 1. PROPER VENTING
 - ENCLOSURES: Recommend 4 each 18 sq.in. vents on opposing sides (Minimum 2 each 18 sq.in. vents).
 - BOWLS (Copper, concrete or metal) Bowl to be raised above mounting surface minimum of 3/4" gap; Bowl to have a minimum of 6" diameter hole in bottom
- 2. GAS SUPPLY FOR USE WITH FIXED PIPING SYSTEMS ONLY NOT FOR USE WITH SMALL TANKS.
 - Natural Gas: Operating Supply Pressure: Minimum: 6.0" W.C.; Maximum: 7.0" W.C.
 - LP Gas: Operating Supply Pressure: Minimum: 10.0" W.C.; Maximum: 11.0" W.C.

IMPORTANT: Ensure any flex line that may be used from the permanent main fuel supply to the product is rated to the stated max btu of the product and certified to ANSI Z21.75*CSA 6.27.

- 3. MODIFCATION OF PRODUCT WILL VOID ANY CERTIFICATION AND WARRANTY.
- 4. FOLLOW ALL MANUFACTURER INSTALLATION INSTRUCTIONS AND LOCAL CODES.
- 5. ALL DIMENSIONS ARE CONSIDERED TRUE AND REFLECT MANUFACTURER'S SPECIFICATIONS AS OF THE REVISION DATE.
- 6. DO NOT SCALE DRAWING.
- 7. THESE DRAWINGS ARE FOR SIZING AND PLANNING PURPOSES. ALL INFORMATION CONTAINED HEREIN WAS CURRENT AT THE TIME OF DEVELOPMENT. THE MANUFACTURER'S RESPONSIBLE FOR THE ACCURACY OF THE DRAWING.
- 8. CONTRACTOR'S NOTE: FOR PRODUCT AND COMPANY INFORMATION VISIT www.CADdetails.com/info REFERENCE NUMBER 771-021.



SIERRA WITH EI FIRE PIT- FLAME SENSING WITH ELECTRONIC HOT SURFACE IGNITION SIERRA WITH MATCH LIT FIRE PIT INSERT

REVISION DATE 11/13/2017